

NECA Comment Matrix for use with Consensus Body Ballots

E: editorial, G: General, T: Technical (Note: Please do not re-size table)

ID: Company with comment # (do not automate comment #)

Page	Line	Clause	E/G/T	Organization	Comment (Rationale)	Proposed Change (Specific; Add, Delete. From-To)	Resolution (SME ONLY)
Entire	Entire		E	ABC	Entire document has many editorial issues ranging from misspellings, use of non-defined terms, incorrectly written phrases to improper sentence structures. Some of this occurs in the same sentence for example see next item.	Have document professionally reviewed by English professional, make corrections and for second ballot. There are too many currently to mark up.	Accepted in principle. The text has been updated and revised.
31	1386	7.1.2	E	ABC	An example of the first comment: <i>By solid fire blocking in accordance with IBC Section 718.2.1 Fireblocking materials.</i>	Standardize on one term and change throughout document. In this example preferably make two separate words.	Accepted.
Entire	Entire		G	ABC	Many places throughout the document "UL" is referred to when the proper term should be Nationally Recognized Testing Laboratory, (NRTL) unless specifically referencing a UL document.	Search and replace UL with NRTL where not specifically referencing a UL publication.	Accepted.
8	NEW	2	G	ABC	Need new definition for NRTL to comply with recommendation immediately above on this list replacing UL with the term NRTL where not specifically referencing a UL publication.	Add the following suggested definition: Nationally Recognized Testing Laboratory (NRTL) – A private sector organization engaged in establishing product standards, testing, and certifying materials and equipment for manufacturers, users and inspection authorities to ensure the products meet an established industry standard necessary for proper installation or use.	Accepted in principle. Definition for NRTL added.
7	307		G	NEBScore	Emphasize distinction between Foam (filler) and firestop Sealant.	Add definition for Fire Barrier Foam: Two-part expanding forming material used to fill annular spacing as an alternative to mineral wool and other forming materials.	Accepted.
c	308		G	NEBScore	Emphasize distinction between Foam (filler) and firestop Sealant.	Add "foam" to listed C in definition of forming materials. Edit to read: Forming Materials: Materials, such as mineral wool, ceramic fiber, backer rod, <u>fire barrier foam</u> and others, that are...	Accepted.

Please think twice about printing this. Please upload this matrix to the online balloting form. Please contact Jeff J. Noren, jeff.noren@necanet.org if you have questions.

